



FRONT



THIS DESIGN IS THE PROPERTY OF  
**KANE ENGINEERING LIMITED**  
 AND MUST NOT BE LENT OR COPIED  
 WITHOUT THE PERMISSION OF  
**KANE ENGINEERING LIMITED**

**KANE ENGINEERING LIMITED**  
 GLENFORD ROAD, NEWWOMARNS, CO. DUBLIN  
 NORTHERN IRELAND BT33 4AU  
 TEL: 028 9181 4465  
 FAX: 028 9181 8900

COLLOUR	RAI. 7035	POLES	3P-N	STANDARD	IEC 60439-1	DESIGNED BY	DK	JOB No. E11207	DRG. No. E11207L
IP	A3	MAIN BUSBAR	800A	VOLTAJE	415V	CHECKED BY	JT	DAISY HILL HOSPITAL, NEWRY	
FORM	4 TYPE 2	IPK	100KA	CABLE ENTRY	TOP	DATE CHECKED		PHASE 2 - BASEMENT	
ACCESS	FRONT	ICW	500KA	CABLE EXIT	TOP	DATE DRAWN		SHEET	
						SCALE	1 OF 1	DRG. TITLE	
						ISSUE	01	SUB SWITCHBOARD	
								PROPOSED LAYOUT	

ISSUE	BY	DATE	MODIFICATION DESCRIPTION	CHECKED BY	DATE